



DAV PUBLIC SCHOOL

UNIT - VIII, BHUBANESWAR, ODISHA

AFFILIATED TO CBSE, NEW DELHI, AFFILIATION No. 1530006, SCHOOL No. 15342

Ref. No. DAV(UNIT-VIII)/ 1099 /2025

Date : 10/05/2025

NOTICE

As per the quotation no DAV (Unit-VIII)/961 dated 21/4/2025 regarding Supply of Fire Fighting Materials at hostel blocks, the tender quoted to be treated as cancelled as only one number of quotation was received by the School.

Therefore once again the sealed tenders will be invited for the purpose through the school website and as well as in the school office during 12/5/2025 , 11:00 am to 19/5/2025 , 3:00 pm ,

The quotation is required to be submitted within 20/05/2025 by 2:00 pm in a sealed envelope mentioning name and phone number stating **"QUOTATION FOR FIRE FIGHTING MATERIALS FOR HOSTEL BLOCK"** on top of the envelope and should be deposited at the reception counter of school. The quotations will be opened on 20/5/2025 at 3:00 pm at the Office of the school.

All the terms and conditions as mentioned in the above quotation will be applicable for this re-quotation too.


10/05/25
PRINCIPAL



DAV PUBLIC SCHOOL

UNIT - VIII, BHUBANESWAR, ODISHA

AFFILIATED TO CBSE, NEW DELHI, AFFILIATION No. 1530006, SCHOOL No. 15342

Ref. No. DAV(UNIT-VIII)/ 961 /2025

Date : 21-04-2025

NOTICE INVITING QUOTATIONS

QUOTATION FOR THE- Supply and Installation of Fire Fighting Accessories with Hose Reel Drum System

Sealed quotations are invited by the undersigned from reputed firms/contractor/agencies for Fire Fighting Accessories with Hose reel Drum system in campus of the school. The interested firms/contractor/agencies may submit their quotations for the purpose of obtaining the prescribed quotation form from the office of the undersigned on all working days from 21/04/2025 to 26/04/2025 between 10:30 am to 01:30 pm. The quotation of the same should be sent in sealed envelope super scribed as "QUOTATION FOR SUPPLY AND INSTALLATION OF FIRE FIGHTING ACCESSORIES WITH HOSE REEL DRUM SYSTEM" on or before 26/04/2025 by 3:30 Pm. The quotation will be opened in the Office of the Principal, DAV PUBLIC SCHOOL, Unit-VIII, and Bhubaneswar at 4:00 Pm on 26/04/2025. The above work will be done for the Hostel blocks in the School Campus.

Terms & Conditions

1. The rate should be inclusive of all GST Charges, Transportation etc
2. There should not be any overwriting or correction in the quotation form.
3. The undersigned does not bind her to accept the lowest quotation and reserves the right to accept the quotation in the whole or in part thereof. The undersigned reserves the right to cancel any or all the quotations without assigning any reason thereof.
4. The quotation received after the stipulated date & time or incomplete in any respect shall not be considered. The quotation without GST shall not be considered.


PRINCIPAL

Copy to :

1. NOTICE BOARD & WEBSITE of the School for information of all concerned
2. PRINCIPAL, DAV PUBLIC SCHOOL, Bhubaneswar & Cuttack with a request to kindly display on notice board & website for information to the public concerned
3. The Concerned file for record

DAV PUBLIC SCHOOL, UNIT-VIII, NAYAPALLI, BHUBANESWAR

PHONE NO-(0674) 2391328,

Date: 21/04/2025

QUOTATION FORM FOR FIXING OF PUMP,PANEL AND 100MM DIA PIPE.

Name of the Agency _____

Address : - _____

PAN No. _____

GST No. _____

Sl No	Name of the Materials	Qty	Rate per Unit	Amount
01	Providing and Fixing main pump, fixing single/double stage horizontal centrifugal pumping set with volute bronze impeller connected to a TEFC induction motor suitable for 410/440 volts 7.5 HP, 3 phase, 50 AC supply. Make-LUBI, Kirloskar of Capacity-450 LPM	02 nos		
02	Providing and Fixing Fire pump AUTO ON OFF control panel	02 nos		
03	Providing and fixing Power Cabling for Pump to Panel	140 Mtr		
04	Providing and fixing case iron dual plate check valves of PN1.6 including nuts, bolts,1.5mm thick compressed asbestos gasket including matching flange, 100mm nominal dia. Kartar.	02 nos		
05	Providing and fixing CI Butterfly valver conforming to PN 1.6/1395 with nuts, bolts, washer,3mm thick insertion, rubber gasket and two matching flanges, 100mm nominal dia. Kartar	06 nos		
06	Providing and fixing dial type pressure gauge with isolation cock and chorme plated copper pipe at hydrant station. Dial Diameter 100 mm caliberation 0-15 Kg/sp.cm	02 nos		
07	Providing and fixing electrically operated dual type pressure switches with threaded connection for a complete suitable for 0-15kg/Sq.cm	02 nos		

08	Providing and fixing brass ball valve with lever and screwed female ends(20kg/cm ²) at all level and position with 15mm and 25mm dia , Type -(Kartar/Zoloto)				
	A	15 mm dia	04 nos		
	B	25 mm dia	12 nos		
09	Supplying and fixing approved make 25m dia automatic air release valve suitable for 20kg/sq cm working pressure with necessary fittings complete in all respect at all level and position. Type - KARTAR/ZOLOTO		02 nos		
10	Installation and fixing first aid Fire Hose Real Drum wall mounting swinging type fitted with 20m dia., B129 30m long high pressure rubber hose. Type- TULSHI FIRE/ FIRE SHIELD/PADMIN		08 nos		
11	Providing & Fixing of Gunmetal collecting head with 63 mm dia instantaneous type inlet and 150 mm dia flanged outlet, fire brigade, connection to fire risers (I.S.904-1965) complete with companion flange with nuts,bolts,gasket, included cutting & Welding at all level and position. Type - TULSHI FIRE/ FIRE SHIELD/PADMIN		02 nos		
12	Supply, Installation and Commissioning of flange jointed/screwed/welded, M.S Pipe of class B (medium class) ISI marked including accessories such as MS bracket, U clamps with Anchor fasteners, tees/elbows/reducers/ couplings / unions/bends/flanges etc. and laying on the surface including painting with two coats of anticorrosive primer and two coats approved red enamel paint after laying and testing after installation etc. as per specifications complete as required 100 mm nominal dia				
	A	25 mm nominal dia	18 Meter		
	B	100 mm nominal dia	72 Meter		

13	Core Cutting, Support, Testing and Handover Charges	As per Actual		
14	Supply , Installation , testing and commissioning of CO2 type Fire Extinguisher 4.5 Kg Capacity with Brass forged Screw down wheel type valve, initial gas charged as per IS 15222, rubber braided discharge hose & Horn, Complete with Accessory as per IS:15683, Wall Mounting bracket with screw and have certification mark engraved. Type: TULSHI FIRE/ AFS/ FIRE TIPS	40 nos		
15	Supply and installation testing and commissioning of ABC Dry Powder Fire Extinguisher 4 Kg Capacity to IS:15683 brass forged squeeze lever discharge valve, fitted with pressure indicating gauge with discharge hose & Well design Plastic discharge nozzle. Make - TULSHI FIRE/ AFS/ FIRE TIPS	30nos		

N.B: a. The above rates should be inclusive of GST

b. Above quantity is on approximate basis, Final Measurement will be as per actual.

c. Transportation charges will be beared by the contractor

Signature with seal of Supplier/Agencies

Address:

Mobile No