

DAV PUBLIC SCHOOL
POKHARIPUT, BHUBANESWAR, ODISHA
(Affiliated to CBSE, New Delhi Vide No-1530065)

Ref. No. DAV/ (PKT)/1687 /2025

Dt.25.08.25

QUOTATION CALL NOTICE

Sealed quotations are hereby invited by the undersigned from the Agencies / Electrical Contractor for renovation of DP Structure including installation of new 250 Kva aluminum wound transformer at the school premises. Interested Parties may submit their quotations as per the Conditions & specification to the undersigned as per separate sheet attached by **3.00 P.M of 3rdth September 2025** in the specific format as noted below. The Quotation will be opened at **3.30 P.M.** on the same day. Incomplete quotations will be treated as invalid and rejected summarily.

Persons submitting quotations must note the following conditions:-


1. Rates are to be quoted for Electric work inclusive of all taxes and transportation.
2. The DAV Public School, Pokhariput, Bhubaneswar does not bind themselves to accept the lowest quotation and reserves the right to accept or reject any quotation without assigning any reason whatsoever.
3. Payment will be made after completion of work subject to verification of the undersigned in person or through the person in charge.
4. If the quality/brand of the materials mentioned in the quotation is not maintained properly the undersigned deserves the right to cancel the order.

Memo No.DAV (PKT)/ 1688 /2025 Dt. 25.08.2025

Copy to:-

1. The Notice Board of the School for information of public/ person concerned on this profession.
2. The Principal of D.A.V. Public Schools, Chandrasekharpur, Unit-VIII, and Kalinga Nagar, Bhubaneswar for their kind information & with a request to kindly take necessary steps to display the Tender Notice on the School Notice Board for information of the person concerned on this profession/ line.
3. The concerned file for record.


PRINCIPAL
D.A.V. Public School
Pokhariput, Bhubaneswar-20
School No. 15337
Affiliation No-1530065


PRINCIPAL
Principal
D.A.V. Public School
Pokhariput, Bhubaneswar-20
School No. 15337
Affiliation No-1530065

Managed By: - DAV COLLEGE MANAGING COMMITTEE, NEW DELHI
Address: Pokhariput, P.O: Aerodrome Area, Bhubaneswar-751020, Phone: 0674-2352392,
Fax: 0674 – 2352428, Email: davpokhariput@gmail.com, Website: www.davpkt.org.in

	Description	Unit	Qty.	Rate in Rs.		Brand/ Make
				Supply	Installation	
Part-A	Renovation of DP Structure					
1	Complete Painting of 2 pole structure for termination of the preparation of the structure surface, primer two coats and finishing alumin paint coats	NOS	1			Asian/Burger
2	Supply, erection and testing of 11KV 400 Amp. Horizontal gang operated A.B. switch including cost of GI pipe handle of appropriate length, nut bolts etc. complete as required.	Set	2			TPCODL App Vendor i.e Indian Power/Sigma/Samal Industries
3	Other miscellaneous work of Substation switch yard inside the Campus & rejoining the structure	Ls	1			
4	Assorted size GI nuts & bolts	Kg	20			
5	metre long 40mm diameter class B perforated GI pipe earth electrode including cost of salt, charcoal, for excavation	SET	2			JSW/ TATA
6	Fabrication and erection of Structure material on existing pole structure made out of fabricated G.I. channels, angles etc.	Kg	100			
					TOTAL	
PART-B	TRANSFORMER					
1	Installation, testing and commissioning of 11/0.433 KV, 250 KVA, air cooled, DY11, Alumn. wound transformer to be installed on existing masonry plinth complete as required.	SET	1			OTPL/OEU/ALFA
2	Laying, testing & commissioning of 3 & 1/2 core 300 sqmm PVC insulated PVC sheathed 1.1 KV grade GI strip armoured aluminum conductor cable. (TFR TODistribution B box)	MTR	40			Havels/ KEI/ Poly Cab
3	Laying, testing & commissioning of 3 core 95 sqmm PVC insulated PVC sheathed 11KV grade GI strip armoured aluminum conductor cable.	MTR	30			
4	Cable End Kit	Set	4			3M
5	Erection, testing & commissioning of L.T. Outdoor floor mounted type distribution board double door type.	No	1			L & T / Legrand
6	Supply, erection and testing of 11KV Load Break Switch with fuse, including cost of nut bolts etc. complete as required.	SET	1			Megawin/ Moby
					TOTAL	
PART-C	LIASONING CHARGES					
1	Professional charges for obtaining permission from TPCODL 250 KVA Sub-station.	EA	1			
2	Professional charges for inspection of Sub Station 2x250 KVA by the Electrical Inspector & drawing approval	EA	1			
					TOTAL	
PART-D	TRANSPOTATION					
1	Transpotation	ls	1			
					TOTAL	
	ABSTRACT					
			Materials	Labour Charges		
Part-A	COST of SUBSTATION DP					
Part-B	TRANSFORMER					
Part-C	LIASONING CHARGES					
Part-D	TRANSPOTATION					
	Sub-Total					
	Total Amount					